WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98466
Permit No.
Basin 176

NOTICE OF INTENT NO. 56159

OWNER HAROLD WYATT
MAILING ADDRESS 5965 NORTH DAPPLE GRAY
LAS VEGAS, NV 89149

ADDRESS AT WELL LOCATION 7 MILES NORTH OF SHANTY
TOWN, RUBY VALLEY
Harrison Drive

2. LOCATION ~~SW~~ 1/4 ~~SE~~ 1/4 Sec. 15 T 28N N/S R 58E E ELKO County
PERMIT NO. SE SW (Issued by Water Resources) 007-03A-036 (Parcel No.) Ruby Lake Est L5 B F (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL/QUARTZ/CLAY		0	70	70
SOFT CLAY MIX WITH		70		
QUARTZ			110	40
GRAVEL	X	110	130	20
SAND & GRAVEL		130	140	10
GRAVEL	X	140	155	15
TAN CLAY		155	160	5

Date started 9/22/2005, 19__
Date completed 9/27/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	48		4

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	19
6	SDR-17		19	160

Perforations:
Type perforation SCREEN
Size perforation .050
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Gravel Packed: [X] Yes [ ] No
From 51 feet to 160 feet

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
26'-50' Bentonite

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 10/3/2005

USE ADDITIONAL SHEETS IF NECESSARY