WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98473
Permit No.
Basin 102

I

NOTICE OF INTENT NO. 55815

1. OWNER Corner Store
MAILING ADDRESS

ADDRESS AT WELL LOCATION 1405 8th St. Silver Springs, NV 89429

2. LOCATION S ¼ SE ¼ Sec. 13 T. 17 N/S R. 24 E. [illegible] County
PERMIT NO. N/A (Issued by Water Resources) 17-261-03 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Boulder		1	3	
Boulders Gravel		3	67	
Clay Some		67	113	
Gravels layers				
Sand, Clay		113	126	
Boulders, Gravel		126	147	
Bedrock		147	163	
Fracture Bedrock (Volcanic)		163	300	
Some fractured layers heavily clay bound.				

RECEIVED

Date started 8/12/05, 20
Date complated 8/13/05, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5 gpm		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	50 Feet
8 3/4 Inches	50 Feet	300 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	188	1	300
6 5/8	PVC	SH40	20	300

Perforations:
Type perforation Mach Perf
Size perforation 3/16 x 6 x 5 # [illegible]
From 200 feet to 220 feet
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 153' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name [illegible] Contractor
Address PO 599 Contractor
S.S. NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [illegible] By driller performing actual drilling on site or contractor

Date 8/19/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627