WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98479
Permit No.
Basin 102

NOTICE OF INTENT NO. 55316

1. OWNER Cornerstone Const.
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1410 Cooney Dr. Silver Springs NV 89429

2. LOCATION SE ¼ SE ¼ Sec. 13 T. 17 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 17-261-14
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Bedding (Coarse)		1	86	
(Volcanic)		86	176	
Bedrock				
fracture				
no clay seams				
fracture		176	238	
Some clay seams				
fractured		238	[redacted]	
			300	

Date started 8/5/05, 20
Date completed 8/6/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12-13		2hrs

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	1 Feet	50 Feet
8 3/4	Inches	50 Feet	[redacted] Feet
	Inches	Feet	300 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	SH 40	20	300
6 5/8	Steel	13/188	1	20

Perforations:
Type perforation 3/16 x 6 x 5#
Size perforation Machine Perf
From 240 feet to 300 feet
From [redacted] feet to [redacted] feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 163' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Contractor
Address Contractor
PO Box 599
S.S. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 18716
Signed
By driller performing actual drilling on site or contractor
Date 8/19/05

RECEIVED

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627