

50 WELLS

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 98542  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28834

1. OWNER Nellis AFB ADDRESS AT WELL LOCATION Nellis Air Force Base Building 60937  
MAILING ADDRESS 99th CES/CEV  
4349 Outer Drive, Nellis AFB, NV 89191  
2. LOCATION NW 1/4 SW 1/4 Sec. 10 T 20 N 62 E CLARK County  
PERMIT NO. R-1306 Parcel No. 140-0-301-001 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ABANDONMENT CONSISTS OF (50) WELLS				
WELLS ARE 1 1/4 GALVANIZED PIPE.				
① PUMP NEAT CEMENT FROM BOTTOM TO TOP OF WELLS.				
② DIG DOWN AND REMOVE TOP 3' OF CASING PER R-1306				
DOWNHOLE RECEIVED				
DEC 23 2005				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION  
Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
Type perforation \_\_\_\_\_  
Size perforation \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
 Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level \_\_\_\_\_ feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WDC Exploration + wells Contractor  
Address 570 Corinthian Way N. Las Vegas, NV 89030 Contractor  
Nevada contractor's license number issued by the State/Contractor's Board 0012852  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 12-27-05

Date started 12-13, 2005  
Date completed 12-15, 2005

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	