WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98570
Permit No.
Basin 99

I

NOTICE OF INTENT NO. 34513

1. OWNER Hans Chirilov
MAILING ADDRESS 25900 Fetlock
Reno, Nv. 89506

ADDRESS AT WELL LOCATION 15105 Red Rock Rd.
Reno, NV 89506

2. LOCATION SW ¼ SW ¼ Sec. 14 T. 23 N/S R. 18 E County
PERMIT NO. WL030165 Issued by Water Resources
078-121-04 Parcel No.
Rancho Haven lot 208 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Semi Solid DG		0	40	40
Harder DG		40	57	17
Semi Solid DG		57	105	48
Black & White Granite		105	135	30
Black & White Granite		135	150	15
Fracture		150	153	3
Black & White Granite		153	170	17
Black & White Orange Granite		170	178	8
Black & White Granite		178	188	10
Fracture H20 3gpm		188	192	4
Black & White Granite		192	205	13
Fracture		205	210	5
Black & White Granite		210	232	22
Fracture H20 15 GPM		232	237	5
Black & White Granite		237	242	5
Broken Granite		242	253	11

Date started 12-10-03, 19
Date completed 12-12-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 253 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To
10 Inches		0 Feet		57 Feet
8⅝ Inches		57 Feet		253 Feet
Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.188	0	253

Perforations:
Type perforation Factory
Size perforation 3/32
From 243 feet to 253 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From 0 feet to 51 feet

9. WATER LEVEL
Static water level 122 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Frank Turner Contractor
Address 472-205 Johnstonville Rd Contractor
Susanville CA 96130
Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2037
Signed By driller performing actual drilling on site or contractor
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627