

OFFICE USE ONLY
 Log No. 98574
 Permit No. _____
 Basin 672

I

PRINT OR TYPE ONLY #16D
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53177

1. OWNER WDC Exploration + Wells ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 580 W. Silver St. Elko, NV 89801 Florida Canyon Mine
P.O. Box 330, Inky 8814
 2. LOCATION NE 1/4 NW 1/4 Sec. 3 T. 31 0/S R 33 E Pershing County
 PERMIT NO. M0246 + 1246A | 08-580-57 | _____
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel & Boulders		0	15	15
Clay & Gravel	150	15	250	
	230			
Water at 230 not to be in well				
Pumped bentonite grout 250 - 205				
With grout cement from 205 - 200				
Put #8 Bentonite Plug 95 - 90				
Pumped pergold grout from 90 - 0				
Put 3 x 3 cement pad & 10" monument				

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 1/2 Inches To 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	PVC	SC40	+1 1/2	200

Perforations:
 Type perforation mill slot
 Size perforation 5 row .20
 From 95 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 45 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 95 feet to 200 feet

Date started 9/8, 2004
 Date completed 9/10, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	95	10

9. WATER LEVEL
 Static water level 159 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration Contractor
 Address P.O. Box 141
Zamora, CA 95698 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 12852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-26-04