WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY #MW2
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98575
Permit No.
Basin Ø72

I

NOTICE OF INTENT NO. 53323

1. OWNER WDC Exploration + Wells
MAILING ADDRESS 580 W. Silver St.
Elko, NV 89801

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NW ¼ Sec. 3 T. 31 N/S R. 33 E. Pershing County
PERMIT NO. M01266 + 12664 (Issued by Water Resources) | 08-580-57 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Broken Rock Gray		0	160	160
Fractured Brown Rock		160	230	70
Gray Silt		230	240	10
Solid Brown Rock	214	240	300	60
Put #8 Bentonite 195 - 190				
Pumped pure gold grout 190 - 0				
Put 3 x 3 cement pad & 10" monument				

RECEIVED 04 NOV -8 PM 1:37 STATE ENGINEERS OFFICE

Date started 8/10, 20 04
Date completed 8/14, 20 04

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		10

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 1/2 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	PVC	SC40	+1 1/2	300

Perforations:
Type perforation mill slot
Size perforation 5 row .20
From 200 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 195
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 195 feet to 300 feet

9. WATER LEVEL
Static water level 214 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration (Contractor)
Address PO Box 141 (Contractor)
Zamora, CA 95698
Nevada contractor's license number issued by the State Contractor's Board 12852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-26-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627