

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 98617  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28408

1. OWNER PARDEE HOMES NV ADDRESS AT WELL LOCATION BUENA VIDA & HORIZON  
 MAILING ADDRESS 10880 WILSHIRE BLVD#1900 RIDGE PKWY  
LOS ANGELES, CA 90024

2. LOCATION NW 1/4 NW 1/4 Sec 36 T 22 S R 61 E CLARK County

PERMIT NO. 177-36-102-006  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Plug 1 domestic well				
Casing 8 5/8"				
Static water level 150'				
Perforate from 100' to 450' we believe that the casing stopped at 450' deep. Ran 8" drill bit to 795' and hit bottom.				
Installed trimmie and placed 17 yards of W171 slurry.				
<b>PLUGGED BY GWMP</b> <b>ORIG/PLUG LOG # 57503</b>				
<b>DCNR/DWR RECEIVED</b>				
<b>JAN 26 2006</b>				
<b>LAS VEGAS OFFICE</b>				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet	Feet
From _____	To _____		
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From	feet to	feet
From _____	_____	_____

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1/6, 20 06  
 Date completed 1/6, 20 06

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
 (CONTRACTOR)  
 Address 4015 WEST TOMPKINS AVE.  
 (CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1/17/06

*Don*