

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 98637  
 Permit No. \_\_\_\_\_  
 Basin 162  
 NOTICE OF INTENT NO. 28365

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER PAHRUMP UTILITY CO. INC ADDRESS AT WELL LOCATION KENSINGTON ST  
 MAILING ADDRESS KENSINGTON ST WELL # 6 E  
PAHRUMP, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 17 T 21S N/S R 54E E NYE County  
 PERMIT NO. 45-171-64 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>DCNR/DWR RECEIVED</b>				
<b>JAN 25 2006</b>				
<b>LAS VEGAS OFFICE</b>				
SILT		0	4	4
SILTY CLAY		4	14	10
CALICHE		14	32	18
CLAY		32	47	15
CALICHE		47	56	9
CLAY		56	65	9
CALICHE	WB	65	80	15
CLAY		80	89	9

8. WELL CONSTRUCTION  
 Depth Drilled 89 Feet Depth Cased 89 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 89 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	.565	.154	0	85

Perforations:  
 Type perforation SCREEN  
 Size perforation .020

From _____	_____ feet to _____	_____ feet
From _____	_____ feet to _____	_____ feet
From _____	_____ feet to _____	_____ feet
From _____	_____ feet to _____	_____ feet
From _____	_____ feet to _____	_____ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 89 feet

9. WATER LEVEL  
 Static water level 74 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. + \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1/9/2006 19  
 Date completed 1/9/2006 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor  
 Address P.O. BOX 4220 Contractor  
PAHRUMP, NV, 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1428  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 1/18/2006