WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98643
Permit No.
Basin 212

NOTICE OF INTENT NO. 29033

1. OWNER LAS VEGAS VALLEY WATER DIST.
MAILING ADDRESS 1001 SOUTH VALLEY VIEW
LAS VEGAS NV 89153

ADDRESS AT WELL LOCATION
S.W. CORNER OF JONES + DESERT INN
WELL # AR-003

2. LOCATION NE ¼ NE ¼ Sec. 14 T. 21 N/S R. 60 E. CLARK County
PERMIT NO. R012/R-1284 (Issued by Water Resources) 163-14-502-001 (Parcel No.) WELL LOG # 43471 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other PLUG

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SOUNDED BOTTOM @ 780'				
SET UP CABLE RIG TO PERFORATE BLANK CASING (PER WAIVER)				
USED MILLS KNIFE TO PERFORATE FROM - TO				
780' - 760'				
520' - 480'				
200' - 100' (BOTTOM OF SEAL)				
SET TREMIE PIPE ON BOTTOM OF HOLE TO PUMP NEAT CEMENT FROM BOTTOM TO SURFACE. PUMPED 30 YARDS NEAT CEMENT.				
WELL HAD 2" SOUNDING TUBE OUT SIDE MAIN CASING - PUMPED 1 YARD IN 2" TUBE				
CUT CASING @ 5' BELOW GRADE AND BACKFILLED TO SURFACE WITH COMPACTED FILL.				

Date started 11-1-, 2005
Date completed 11-14-, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
DEC 8 - 2005
LAS VEGAS OFFICE

WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WEBER GROUP LC (Contractor)
Address 16825 S. WEBER DRIVE (Contractor)
CHANDLER AZ - 85226
Nevada contractor's license number issued by the State Contractor's Board 035639
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2221
Signed Allen L Hodgkins (By driller performing actual drilling on site or contractor)
Date 12-1-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627