WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98644
Permit No.
Basin 212

NOTICE OF INTENT NO. 29032

1. OWNER LAS VEGAS VALLEY WATER DIST.
MAILING ADDRESS 1001 S. VALLEY VIEW
LAS VEGAS NV 89153
ADDRESS AT WELL LOCATION S.W. CORNER OF JONES + DESERT INN
WELL # AR002

2. LOCATION NE ¼ NE ¼ Sec. 14 T. 21 N/S R. 60 E. CLARK County
PERMIT NO. R012 / R-1284 (Issued by Water Resources) 163-14-502-001 (Parcel No.) WELL LOC # 43470 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other PLUG

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ ~~Municipal~~/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SOUNDED FILL IN WELL @ 784' | | | | |
| BAILED DEBRIS OUT TO BOTTOM @ 780' | | | | |
| USE MILL KNIFE TO PERFORATE BLANK CASING (PER WAIVER) | | | | |
| PERFORATED FROM - TO | | | | |
| 780' - 760' | | | | |
| 520' - 480' | | | | |
| 200' - 115' (BOTTOM OF SEAL) | | | | |
| BAILED WELL FROM 764' TO 780' | | | | |
| SET TREMIE TO BOTTOM AND PUMPED 30 YARDS OF NEAT CEMENT FROM BOTTOM TO SURFACE | | | | |
| WELL HAD 2" SOUNDING TUBE ON OUTSIDE OF CASING - PUMPED 1 YARD OF NEAT CEMENT INTO 2" TUBE. | | | | |
| CUT CASING AT 5' BELOW SURFACE AND BACKFILL WITH COMPACTED FILL. | | | | |

Date started 11-1, 2005
Date completed 11-14, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

DCNR/DWR
RECEIVED
DEC 8 - 2005

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WEBER GROUP LC (Contractor)
Address 16825 S. WEBER DRIVE (Contractor)
CHANDLER AZ 85226
Nevada contractor's license number issued by the State Contractor's Board 035639
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 3221
Signed Allan L Hardy Jr (By driller performing actual drilling on site or contractor)
Date 12-1-05

(Rev. 12-01) LAS VEGAS OFFICE USE ADDITIONAL SHEETS IF NECESSARY (O)-627