

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26927

1. OWNER Metroflag Management ADDRESS AT WELL LOCATION 3755 S. LV Blvd.  
 MAILING ADDRESS 3755 Howard Hughes Pkwy  
Las Vegas, NV 89109  
 2. LOCATION NW 1/4 SW 1/4 Sec. 21 T. 21 N/S R. 61 E. Clark County  
 PERMIT NO. 162-21-301-018 Parcel No. 28 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Asphalt</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Gravelly sand</u>		<u>5</u>	<u>2</u>	<u>1.5</u>
<u>Silty sand w/gravel</u>		<u>2</u>	<u>6</u>	<u>4</u>
<u>Sandy clay</u>		<u>6</u>	<u>11</u>	<u>5</u>
<u>Silty sand w/clay</u>		<u>11</u>	<u>12</u>	<u>1</u>
<u>Clay</u>		<u>12</u>	<u>16</u>	<u>4</u>
<u>gravel</u>		<u>16</u>	<u>24</u>	<u>8</u>
<u>Caliche</u>		<u>24</u>	<u>27</u>	<u>3</u>
<u>Silty clay w/gravel</u>		<u>27</u>	<u>35</u>	
<u>Caliche</u>		<u>35</u>	<u>39</u>	<u>4</u>
<u>Clay</u>		<u>39</u>	<u>50</u>	
<u>Caliche</u>		<u>50</u>	<u>62</u>	<u>12</u>
<u>Clay w/gravel layers</u>		<u>62</u>	<u>75</u>	<u>12</u>

DCNR/DWR  
 RECEIVED  
 JAN 26 2006

8. WELL CONSTRUCTION  
 Depth Drilled 75 Feet Depth Cased 75 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 75 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>75</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation 0.20  
 From 40 feet to 75 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 38 to surface  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 38 feet to 75 feet

9. WATER LEVEL  
 Static water level 23 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Elite Drilling Inc.  
 Address 4255 W. Post rd.  
Las Vegas, NV 89118  
 Nevada contractor's license number issued by the State Contractor's Board 0054931  
 Nevada driller's license number issued by the Division of Water Resources M-1869  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-24-06

Date started 1-18 2006  
 Date completed 1-18 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			