DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

I

Office use only
Log No. 98664
Permit No.
Basin 099

NOTICE OF INTENT NO 56215

1. OWNER **Bill Reeves**
MAILING ADDRESS **250 Quarterhouse**
Reno, NV

ADDRESS AT WELL LOCATION **250 Quarterhouse**

2. Location **NW** 1/4 **SW** 1/4 Sec **10** T **23** N R **18E** **Washoe** County
PERMIT NO. PARCEL NO. **078-201-21** SUBDIVISION NAME

3. WORK PERFORMED
x New Well | Replace | Recondition
Deepen | Abandon | Other

4. PROPOSED USE
X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE
Cable | X Rotary | RVC
Air | Other | x Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand.		**0**	**3**	**3**
				0
Clay & sand.		**3**	**17**	**14**
				0
White granite		**17**	**31**	**14**
				0
Soft granite.	35	**31**	**140**	**109**
				0
Hard granite.		**140**	**182**	**42**
				0
Black granite / clay.		**182**	**320**	**138**
				0
Hard white granite / small fractures.		**320**	**413**	**93**
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

8. WELL CONSTRUCTION
Depth Drilled **413** feet Depth Cased **413** feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	inches	**0**	feet	**55**	feet
8 3/4	inches	**55**	feet	**413**	feet
	inches		feet		feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	**12.94**	**188**	**+1 1/2**	**413**

Perforations::
Type Perforation **Factory**
Size perforation **3/32 x 3"**
From **293** feet to **313** feet
From **333** feet to **353** feet
From **373** feet to **413** feet
From feet to feet
From feet to feet

Surface Seal **X** YES No
Depth of Seal **50** feet
x Pumped
Poured
Gravel Packed: X Yes No
From **50** feet to **413** feet

Seal Type:
Neat Cement
x Cement Grout
Concrete Grout

9 WATER LEVEL
Static water leve**60** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

Date started **8-22** -05
Date completed **8-30** -05

7. WELL TEST DATA
TEST METHOD: Bailer Pump x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
10	140	1
15	**180**	**1**
25	350	2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2292**
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 9-7 -05