

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 98668
 Permit No. _____
 Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55666

1. OWNER Tio Esquivel
 MAILING ADDRESS 3065 Mars
Winnemucca, NV 89445
 ADDRESS AT WELL LOCATION 7060 Torrey lane
Winnemucca, NV 89445

2. LOCATION Parcel
D $\frac{1}{4}$ NW $\frac{1}{4}$ Sec 18 T 35 N R 38 E Humboldt County
 PERMIT NO. 010-611-08
 Issued by Water Resources Parcel No. 010-611-08 Subdivision Name Tycana subdivision

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Cobles and Gravel		3	15	12
Boulders		15	25	10
Gravel		25	30	5
Cobles		30	55	25
Ledge		55	60	5
Cobles		60	80	20
Gravel		30	90	10
Boulders		90	95	5
Cobles		95	103	8
Boulders		103	120	17
Cobles and Gravel		120	135	15
Boulders		135	150	15
Cobles and gravel		150	165	15
Sand and Gravel		165	170	5
Cobles and gravel		170	180	10
Boulders		180	200	20
Sand and Gravel		200	210	10
Boulders		210	215	5
Ledge		215	220	5
Cobles, gravel and sand		220	245	25
Boulders		225	250	5

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 246 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	10	.188	+1	20
6.625	4.06	.316	20	206

Perforations:
 Type perforation screen
 Size perforation .050
 From 206 feet to 246 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 67 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 67 feet to 247 feet

9. WATER LEVEL
 Static water level 165 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson & Sons Drilling, Inc.
 (CONTRACTOR)
 Address 10760 Grass Valley Road
 (CONTRACTOR)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed _____
 By driller performing actual drilling on site or contractor
 Date July 20, 2005

Date started July 11, 20 05
 Date completed July 13, 20 05

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>4</u>

RECEIVED
 05 JUL 21 AM 10:57
 STATE ENGINEERS OFFICE