COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98671
Permit No.
Basin 101

NOTICE OF INTENT NO. 53132

1. OWNER CASEY PROPERTIES
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 9393 MARSHALL
FALLON, NV 89406

2. LOCATION ~~E 1/2~~ ¼ SE ¼ Sec 15 T 19 N R 27 E CHURCHILL County

PERMIT NO. NW (Issued by Water Resources) | 007-171-66 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	8	8
BROWN CLAY		8	20	12
BROWN SANDS		20	35	15
BROWN CLAY		35	40	5
BROWN SANDS		40	50	10
GRAY SANDS		50	70	20
GRAY CLAY		70	75	5
GRAY SANDS		75	90	15
GRAY CLAY		90	94	4
BROWN SANDS & GRAVEL	X	94	113	9

RECEIVED
05 SEP 12 AM 10:38
STATE ENGINEERS OFFICE

Date started JULY 25, 20 05
Date completed JULY 25, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION

Depth Drilled 113 Feet Depth Cased 113 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	113 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	113

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 107 feet to 111 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 37'2" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date AUGUST 23,2005

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com