COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98672
Permit No.
Basin 101

I

NOTICE OF INTENT NO. 55969

1. OWNER LANCE WEGAR
MAILING ADDRESS 3090 SILVERSTATE AVE
FALLON, NV 89406

ADDRESS AT WELL LOCATION BRIGGS LANE
FALLON, NV 89406 1233

2. LOCATION ~~SE~~ SE ¼ ~~NW~~ NW ¼ Sec ~~20~~ 20 T 19 N R 28 E CHURCHILL County

PERMIT NO. | Issued by Water Resources | Parcel No. 008-532-43 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	12	10
BROWN SILT CLAY		12	40	28
GRAY SANDS		40	80	40
GRAY CLAY		80	83	3
GRAY SANDS		83	120	37
GRAY CLAY		120	140	20
BROWN SANDS	X	140	155	15

RECEIVED
SEP -2 AM 8:33
STATE ENGINEER'S OFFICE

Date started JULY 26, , 20 2005
Date completed JULY 26 , 20 2005

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		1 HR

8. WELL CONSTRUCTION

Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	155 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	155

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 149 feet to 153 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 31'3" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date AUGUST 24,2005

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com