COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98687
Permit No.
Basin 101

I

NOTICE OF INTENT NO. ~~53100~~ 53114

1. OWNER CASEY PROPERTIES
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1850 PAM
FALLON NV 89406

2. LOCATION NW ¼ NW ¼ Sec 20 T 19 N R 28 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) 008-172-27 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	12	11
BROWN CLAY		12	18	6
BROWN SAND		18	38	20
BROWN CLAY		38	42	4
GRAY SANDS		42	70	28
GRAY CLAY		70	72	2
GRAY SANDS		72	89	17
GRAY CLAY		89	90	1
BROWN SAND	X	90	103	13

RECEIVED
05 JUN 10 AM 11:57
STATE ENGINEERS OFFICE

Date started APRIL 21, 20 05
Date completed MAY 23, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION

Depth Drilled 103 Feet Depth Cased 103 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
103/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	103 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
65/8	12.9	.188	+2	103

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 97 feet to 101 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 20'9" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date JUNE 8, 2005

Forms Provided by Forms-On-A-Disk, Inc. - (214) 340-9429 - FormsOnADisk.com