WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98689
Permit No. 14202 - D8B
Basin 212

NOTICE OF INTENT NO. 27883

1. OWNER School Board of Trustees
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1734 BALZAR AVE, LV. NV. 89106

2. LOCATION NE ¼ NW ¼ Sec. 21 T 20 S N/S R 61 E CLARK County
PERMIT NO. ~~15477~~ already 14202 Issued by Water Resources
Parcel No. 139-21-102-009
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☒ ~~Irrigation~~ ☐ Test
☒ ~~Municipal/Industrial~~ ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled Turbine Pump				
No Debris				
Well 385 ft Deep				
Well 10" Diam Heavy Wall				
Pump Column For Casing.				
Perferated From 385 ft				
UP-TO-SURFACE FOUR TIMES				
AROUND WITH AIR PERFERATOR				
Pumped in 30 yds of Neat				
Cement. Div. of Water				
Resources Rep Was There.				

DCNR/DWR
RECEIVED
SEP 26 2005
LAS VEGAS OFFICE

PLUGGED BY GWMP
ORIG PLUG LOG # ~~2000~~ 2136

Date started 09-09-05, 20
Date complated 09-15-05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2006 APR 19 A 10:30
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 39 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Contractor
Address 5360 N. Bonita Vista St.
Contractor
LV. NV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V A Dimick
By driller performing actual drilling on site or contractor
Date 09-26-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627