WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98690
Permit No.
Basin 212

NOTICE OF INTENT NO. 29233

1. OWNER Tonapah 45 LLC
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1798 COVEY LN - DSB

2. LOCATION SW ¼ SW ¼ Sec. 19 T. 20S N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 140-19-402-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon Well. with 8 5/8 steel casing				
of .156. Drill out Rock wood and Iron.				
Fish out pump pipe. Drillout to				
105 ft. Bottom of hole is 105 Ft.				
Perferate from Bottom up to 50 ft.				
Cement from bottom up to -3 ft.				
27 sack slurry.				
County required Builders to				
Exevate down 10 Ft. around hole.				

DCNR/DWR
RECEIVED
DEC 20 2005
LAS VEGAS OFFICE

Date started 12/16/05, 19
Date completed 12/19/05, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St. (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 12-20-05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627