


WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98692
Permit No. _____
Basin 789



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 49864

1. OWNER NICK BROWN ADDRESS AT WELL LOCATION SAME
MAILING ADDRESS 3040 PARSHINS LN. Reno, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 6 T. 16 S. R. 20 E WASHOE County
PERMIT NO. N/A Issued by Water Resources 050-424-05 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Reconition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Well was abandoned on 5/4/05</u>				
<u>Attempt to pull well casing failed</u>				
<u>Well was perforated from 62 ft to 45 ft</u>				
<u>A 6 inch mill pipe was used to perforate the 6 5/8" well</u>				
<u>4 perforator per ft</u>				

8. WELL CONSTRUCTION
Depth Drilled 62 Feet Depth Cased _____ Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8
Perforations:
Type perforation _____
Size perforation _____
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 45
Placement Method: Pumped Poured
Gravel Packed: Yes No
From _____ feet to _____ feet

Date started 5/4/05 19____
Date completed 5/4/05 19____

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name William Knoblock + Sons Contractor
Address 5425 Spanish Mass Sparks NV 89436 Contractor
Nevada contractor's license number issued by the State Contractor's Board 49162
Nevada driller's license number issued by the Division of Water Resources, the on-site driller AB 2213
Signed William Knoblock By driller performing actual drilling on site or contractor
Date 6/21/05