WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98699
Permit No.
Basin 131

NOTICE OF INTENT NO. 56238

1. OWNER Newmont Mining Co.
MAILING ADDRESS P.O. Box 3881
Valmy, NV 89438

ADDRESS AT WELL LOCATION Mule Canyon Mine MV-1359

2. LOCATION SE ¼ SE ¼ Sec. 3 T. 31 N/S R. 41 E. Lander County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium, Boulders		0	20'	
Hard rock		20'	660'	
Set 655' of 4" sch 80 PVC				
Tripped in trimmy & poured 1½				
Super sack of ¼ minus gravel pack				
from 660' to 593'.				
Dumped 1½ super sacks of				
3/8" chip from 593' to 50'				
Poured 120 Gal of cement grout				
from 50' to 0' seal.				
20-sacks of 94lb Portland cement				
monument 2'10" above ground level				

Date started October 25, 2005
Date completed October 27, 2005

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 660 Feet Depth Cased 655 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0'	Feet	20'	Feet
8	Inches	20'	Feet	660'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sch 80	0'	660'

Perforations:
Type perforation slotted
Size perforation .020
From 595' feet to 655' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 660' feet to 593' feet

9. WATER LEVEL
Static water level 588' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co. (Contractor)
Address P.O. Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2291
Signed (By driller performing actual drilling on site or contractor)
Date 10-27-05

2005 NOV 28 PM 1:56
RECEIVED
STATE ENGINEER'S OFFICE

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627