

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55761

1. OWNER Newmont Mining Co. ADDRESS AT WELL LOCATION Mule Canyon
 MAILING ADDRESS P.O. Box 3981 M.A.R. MW-1357
Valmy, NV 89438
 2. LOCATION NW 1/4 NW 1/4 Sec. 4 T 31 N 41 E Lander County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Bed rock</u>		<u>0'</u>	<u>320'</u>	
<u>Set 315' of 4" sch 80 PVC</u>				
<u>Tripped in 260' of running</u>				
<u>& poured 1/2 super sack of</u>				
<u>1/4 minus gravel pack from 320'</u>				
<u>to 253'</u>				
<u>Dumped 67 50lb. bags of</u>				
<u>1/2 chip from 253' to 50'</u>				
<u>Poured 120 bal of cement grout</u>				
<u>from 50' to 0' - 20 sacks of</u>				
<u>44 lb Portland cement</u>				
<u>monument 2' 8" above ground level</u>				

8. WELL CONSTRUCTION
 Depth Drilled 320' Feet Depth Cased 315' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches 0' Feet 20' Feet
 To 8 Inches 20' Feet 320' Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>SCH 80</u>	<u>0</u>	<u>320</u>

Perforations:
 Type perforation slotted
 Size perforation 1020
 From 255 feet to 320' feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 320' feet to 253' feet

9. WATER LEVEL
 Static water level 300' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started October, 19 2005
 Date completed October, 21 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw-Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eklund Drilling Co. Contractor
 Address P.O. Box 2748 Contractor
ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11-2291
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10-21-05