

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28763

1. OWNER Wayne Rose ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS H.C. 69 Box 450 E 1208 Joshua St.  
Amargosa Valley, NV. 89020 Amargosa Valley, NV. 89020  
 2. LOCATION NW 1/4 SW 1/4 Sec. 16 T. 16 N. R. 48 E. County \_\_\_\_\_  
 PERMIT NO. 719-041-14 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand w/ small gravel</u>		<u>0</u>	<u>115</u>	<u>115</u>
<u>large gravel with sand layers</u>	<u>-152</u>	<u>115</u>	<u>197</u>	<u>82</u>
<u>Bottom of well</u>			<u>197</u>	

DCNR/DWR  
 RECEIVED  
 JAN 13 2006  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 197 Feet Depth Cased 197 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 197 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>197</u>
<u>8</u>	<u>Steel</u>	<u>.188</u>	<u>7</u>	<u>7</u>

Perforations:  
 Type perforation Machined  
 Size perforation 6R .032 screen, 4R 1/8" Every 12"  
 From 137 feet to 177 feet  
 From 177 feet to 187 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 197 feet

9. WATER LEVEL  
 Static water level 117 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Cook Drilling Co. Contractor  
 Address H.C. 70 Box 543 Contractor  
Amargosa Valley, NV. 89020  
 Nevada contractor's license number issued by the State Contractor's Board 5326-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160  
 Signed Red [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9/12/05

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Date started 7/27, 2005  
 Date completed 8/19, 2005