

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53517

1. OWNER James KOZEN ADDRESS AT WELL LOCATION 1554 ALBAVISTA
MAILING ADDRESS 7373 Almaden LN Gardnerville NV
Carlsbad, CA 92009

2. LOCATION SE 1/4 SW 1/4 Sec. 18 T 10 N/S R 23 E Douglas County County
PERMIT NO. 1022-18-002-047 Lot 14 Subdivision Name _____
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loose Gravel Brown, Red		0	18	18
Boulder, Red Brown		18	22	4
Clay & Gravel Red Brown + white		22	38	16
Clay, Sand Brown		41	105	64
Gravel Red Brown White Water		105	118	13
Rock Soft Brown White		118	160	42

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
From To
11 Inches 0 Feet 50 Feet
10 1/4 Inches 50 Feet 150 Feet
6 Inches 150 Feet 160 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 9/8</u>	<u>13</u>	<u>0.188</u>	<u>+1'</u>	<u>160</u>

Perforations:
Type perforation Factory
Size perforation 1/8 x 3"

From _____ feet to _____ feet
From 80 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow N-A G.P.M. N-A P.S.I.
Water temperature Cool °F Quality _____

Date started 3-23, 2004
Date completed 5-10, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>10+</u>	<u>8</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Santori Development Contractor
Address PO Box 7119 Contractor
Gardnerville NV 89460

Nevada contractor's license number 8-2-0056884
issued by the State Contractor's Board 623-0057531

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652

Signed George E. Steele
By driller performing actual drilling on site or contractor

Date _____

RECEIVED
04 JUN +9 AM 10:49
STATE ENGINEERS OFFICE