WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98829
Permit No.
Basin 212

NOTICE OF INTENT NO. 28253

1. OWNER Korean American Presbyterian Church
MAILING ADDRESS 6554 W Desert Inn Rd Las Vegas NV 89102
ADDRESS AT WELL LOCATION 6554 W Desert Inn Rd, Las Vegas NV 89102

2. LOCATION SW ¼ SW ¼ Sec. 11 T. 21 N/S R. 60 E. Clark County
PERMIT NO. ____ Issued by Water Resources | 163-11-405-013 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned 9" well to 200' Depth. Reamed debris from well from 10' to 200' Existing Perforations from 100' to 200'. Peforated casing from 30' to 100' and pumped in 3 yards of neat cement through a tremmie line to 170'. Then filled well with clean fill to 180' and poured a 20' surface plug of neat cement to completely fill well.				

DCNR/DWR
RECEIVED
FEB 14 2006
LAS VEGAS OFFICE

Date started 2-2-, 2006
Date completed 2-13-, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200. Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
9"			0	200

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. - Water Well Drilling (Contractor)
Address 2870 W Pebble Rd. Las Vegas NV 89123 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1737-T2
Signed ____ (By driller performing actual drilling on site or contractor)
Date 2-13-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627