

OFFICE USE ONLY
 Log No. 98830
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29249

1. OWNER Mission Complete Contractors ADDRESS AT WELL LOCATION 6760 Surrey St.
 MAILING ADDRESS 6754 Spencer St. Las Vegas NV 89119 Las Vegas NV 89119

2. LOCATION NE 1/4 NE 1/4 Sec. 02 T. 22 N. R. 61 E Clark County
 PERMIT NO. 177-02-602-014 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned 9" well to 135' Depth.				
Fished out and removed Pump, motor and drop pipe.				
Existing Perforations from 35' to the Bottom.				
Perforated from 40' to the top of well and pumped in 3 yards of neat cement in through a tremmie line which completely filled the well.				
DCNR/DWR RECEIVED				
FEB 21 2006				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 135 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>9</u>				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 27' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2/6, 2006
 Date completed 2/16, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: T-D-C. Water Well Drilling Contractor
 Address: 2870 W Pebble Rd Contractor
Las Vegas NV 89123

Nevada contractor's license number issued by the State Contractor's Board 59948
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1737-I-1

Signed W. Daniel Astrey
 By driller performing actual drilling on site or contractor
 Date 2/16/06