

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28251

1. OWNER Frontier Hotel and Casino ADDRESS AT WELL LOCATION 3120 Las Vegas Blvd South, Las Vegas NV 89109  
 MAILING ADDRESS 3120 Las Vegas Blvd South, Las Vegas NV 89109  
 2. LOCATION SW 1/4 SW 1/4 Sec. 9 T. 21 N. R. 61 E. Clark County  
 PERMIT NO. 42781, 42782, 42783, 162-16-101-004 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned 12" well to 570' depth.				
Attempted to pull 10" Linner inside well. Refer well log # 88010.				
Unable to pull linner. Original well has collapsed onto linner.				
Existing perforations on 10" Linner has 304' of screen.				
From 237' to 541'				
We Perforated linner from 237' to 10 ft from surface and pumped 20 yards of neat cement in through a tremie line which completely filled well.				
Refer waiver # R-1310.				
DONOR RECEIVED FEB 7 2006 LAS VEGAS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 541 Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1/18/06  
 Date completed 2/6/06

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name T.D.C. water well Drilling Contractor  
 Address 2870 W Pebble Rd, Las Vegas NV 89123 Contractor  
 Nevada contractor's license number 59948 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1737-T1  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 2/6/06