WHITE - DIVISION OF WATER RESOURCES
~~CANARY~~ - CLIENT'S COPY
~~PINK~~ - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
~~DO NOT WRITE~~ ON BACK

~~STATE OF NEVADA~~
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98841
Permit No.
Basin 162

NOTICE OF INTENT NO. 29604

1. ~~OWNER~~ RANDALL PASQUALETTO
MAILING ADDRESS 141 W SIMKINS RD

ADDRESS AT WELL LOCATION 141 W SIMKINS RD

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 29-881-11 (Parcel No.) BELL VISTA 3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT		0	4	4
CLAY		4	21	17
CALICHE		21	36	15
CLAY		36	65	29
CALICHE		65	71	6
SILT	WB	71	82	11
CLAY		82	140	58
CALICHE	WB	140	165	25
CLAY		165	171	6
CALICHE	WB	171	178	7
SILT	WB	178	180	2

DCNR/DWR
RECEIVED
MAR 17 2006
LAS VEGAS OFFICE

Date started 3/6/2006 , 19__
Date completed 3/6/2006 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 120 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the ~~best of my knowledge~~.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (~~Contractor~~)
PAHRUMP,NV. 89048
~~Nevada contractor's license number~~ issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 3/9/2006

USE ADDITIONAL SHEETS IF NECESSARY