WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98851
Permit No.
Basin 162

NOTICE OF INTENT NO. 29628

OWNER CARL & MAY JONAS
MAILING ADDRESS 2311 W AMBLER WAY
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2311 W AMBLER WAY

2. LOCATION NE 1/4 NE 1/4 Sec. 19 T 19S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 09-442-09 (Parcel No.) VALLEY VIEW ACRES (Subdivision Name)

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY | | 0 | 67 | 67 |
| CALICHE | WB | 67 | 73 | 6 |
| CLAY | | 73 | 104 | 31 |
| CALICHE | WB | 104 | 126 | 22 |
| CLAY | | 126 | 163 | 37 |
| CALICHE | WB | 163 | 174 | 11 |
| CLAY | | 174 | 200 | 26 |

DCNR/DWR
RECEIVED
MAR 23 2006
LAS VEGAS OFFICE

Date started 3/20/2006 , 19__
Date completed 3/20/2006 , 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**
Depth Drilled 200 Feet Depth Cased 200 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 200 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | .250 | 0 | 200 |
| | | | | |
| | | | | |

**Perforations:**
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

**9. WATER LEVEL**
Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on-site or contractor
Date 3/22/2006

USE ADDITIONAL SHEETS IF NECESSARY