WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98865
Permit No. 79793
Basin 212

NOTICE OF INTENT NO. 29248

1. OWNER Anthony Pasqualotto
MAILING ADDRESS 5775 S. Duneville St.
Las Vegas NV 89118

ADDRESS AT WELL LOCATION N/A

2. LOCATION NE ¼ SW ¼ Sec. 35 T. 21 N/S R. 60 E. Clark County
PERMIT NO. SE NW (Issued by Water Resources) 163-35-202-018 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0'	9'	9'
Large Boulders		9'	22'	13'
Soft Caliche		22'	36'	14'
Gray clay + Gravel		36'	118'	82'
Soft Red Rock		118'	193'	75'
Soft Caliche + Red Clay		193'	256'	63'
Gravel + red sand		256'	377'	121'
Hard Caliche		377'	408'	33'
Gravel + Red and White sand		408'	515'	107'
Hard Caliche		515'	523'	8'
Red sand + Gravel		523'	558'	32'

DCNR/DWR
RECEIVED
MAR 30 2006
LAS VEGAS OFFICE

Date started March 6th, 2006
Date completed March 29th, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
32		

8. WELL CONSTRUCTION
Depth Drilled 558 Feet Depth Cased 558 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	558 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	PVC			

Perforations:
Type perforation Factory P.V.C.
Size perforation
From 458' feet to 558' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 558 feet

9. WATER LEVEL
Static water level 307 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C Water Well Drilling (Contractor)
Address 2870 W. Pebble Rd (Contractor)
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1737-T1
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3/30/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627