

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28673

1. OWNER TITANIUM METALS CORP. ADDRESS AT WELL LOCATION SAME
 MAILING ADDRESS 2000 W. LAKE MEAD BLVD
HENDERSON NV 89052
 2. LOCATION SE 1/4 NE 1/4 Sec. 22 T. 22 S. N/S R. 62 E CLARK County
 PERMIT NO. 173-12-701-002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other SPUR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Silty Sand	30	0	24	24
Broken Caliche Frag		24	25	1
Brown Silty Sand		25	26	1
Brown Sand		26	32	6
Brown Clayey Sil		32	39	7
Brown Clay Sand		39	40	1
Brown Clayey Sil		40	41	1

DCNR/DWR
 RECEIVED
 MAR 21 2006
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 41 Feet Depth Cased 39 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8.5 Inches To 41 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.0</u>		<u>.237</u>	<u>0</u>	<u>19</u>

Perforations:
 Type perforation MACHINE CUT
 Size perforation 0.020
 From 19 feet to 39 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 17 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 17 feet to 39 feet

9. WATER LEVEL
 Static water level 27.09 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62.2 °F Quality _____

Date started 12/17, 2005
 Date completed 12/17, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PROSPERITY CORP. Contractor
 Address 419 E. JAWAHL AVE MEAD Contractor
AZ 85204
 Nevada contractor's license number issued by the State Contractor's Board 0015765
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1988
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3/17/06