

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28679

1. OWNER TITANIUM META CORP. ADDRESS AT WELL LOCATION SAME  
 MAILING ADDRESS 8000 W. LAKE MESA BLVD  
HENDERSON NV 89052  
 2. LOCATION SE 1/4 NE 1/4 Sec. 18 T. 22N N/S R. 62 E CLARK County  
 PERMIT NO. 179-18-101-005 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Red/Yellow Silty Sand</u>		<u>0</u>	<u>1</u>	<u>1'</u>
<u>BROWN SILTY SAND, coarse</u>		<u>1</u>	<u>19</u>	<u>18'</u>
<u>BROWN SILTY SAND, coarse</u>	<u>75'</u>	<u>19</u>	<u>93</u>	<u>74'</u>
<u>BROWN CLAY/SILT, SAND</u>		<u>93</u>	<u>96</u>	<u>3'</u>
<u>BROWN SILTY SAND, coarse</u>		<u>96</u>	<u>100</u>	<u>4'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 95 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8.5 Inches To 100 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>.237</u>	<u>0.0</u>	<u>65</u>

 Perforations:  
 Type perforation MACHINE CUT  
 Size perforation 0.00  
 From 65 feet to 95 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 51 feet to 95 feet  
 9. WATER LEVEL  
 Static water level 74.43 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.0 °F Quality \_\_\_\_\_

Date started 12/13, 2005  
 Date completed 12/13, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PROSONIC CORP. Contractor  
 Address 419 E JUANITA AVE MESA Contractor  
AZ 85204  
 Nevada contractor's license number issued by the State Contractor's Board 0015765  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1988  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3/17/06