

OFFICE USE ONLY
 Log No. 98918
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28464

1. OWNER Brian Mahoney - Silver Nugget Casino ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2140 N. Las Vegas Blvd. N. Las Vegas NV 89030 2236 N. Las Vegas Blvd.
 2. LOCATION NW 1/4 NE 1/4 Sec. 23 T 20 R 61 E Clark County
 PERMIT NO. 139-23-504-902
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

6. LITHOLOGIC LOG MW-5

Material	Water Strata	From	To	Thick-ness
<u>Asphalt pavement</u>				
<u>over sandy gravel</u>		<u>0</u>	<u>6</u>	
<u>SILTY CLAY - w/gyp</u>		<u>6</u>	<u>10</u>	
<u>SILTY CLAY - p.c.</u>		<u>10</u>	<u>16.5</u>	
<u>CALICHE</u>		<u>16.5</u>	<u>21</u>	
<u>SANDY CLAY</u>	<u>Y</u>	<u>21</u>	<u>34</u>	

8. WELL CONSTRUCTION
 Depth Drilled 34 Feet Depth Cased 34 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches 0 Feet 34 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>sch. 40</u>	<u>0</u>	<u>34</u>

 Perforations:
 Type perforation slotted screen
 Size perforation .010 - inch
 From _____ feet to _____ feet
 From 19 feet to 34 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 17 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 17 feet to 34 feet

Date started 2/15, 2006
 Date completed 2/15, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 19.87' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Tim Allen Contractor
 Address 4343 S. Polovin Ave. LV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2155
 Signed Tim Allen
 By driller performing actual drilling on site or contractor
 Date 2/21/06