

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56039

1. OWNER Charles Brown ADDRESS AT WELL LOCATION Lat 38° 57' 47" Long 115° 11' 32"  
 MAILING ADDRESS HC 34 Box 34167  
ELY NV 89301

2. LOCATION NW 1/4 NE 1/4 Sec 33 T 13 N/S R 60 E White Pine County  
 PERMIT NO. N/A Issued by Water Resources Parcel No. 11-210-09 N/S R 60 E White Pine County  
4.510.03 Non Subdivision Name OS PER F.I.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	
Clay cobbles gravel		2	10	
Clay gravel		10	25	
Clay		25	35	
Clay conglomerate		35	65	
gravel con.		65	75	
Clay gravel con.		75	175	
gravel	water	175	176	
Clay gravel con		176	184	
gravel	water	184	186	
Clay gravel con		186	194	
gravel	water	194	195	
Clay gravel con		195	210	
gravel	water	210	211	
Clay gravel con		211	260	

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10	0	50		
8	50	260		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	12.9	.188	-1	19
4		Sch 40 PPL	19	260

Perforations:  
 Type perforation MILL CUT  
 Size perforation 1.032 x 6.000  
 From 180 feet to 220 feet  
 From 240 feet to 260 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 143 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

Date started Nov 15 2005  
 Date completed Dec 20 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22	72	1 hr

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor  
 Address Po Box 64 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 47226  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554

Signed Owner Maynard  
 By driller performing actual drilling on site or contractor  
 Date Jan 10 - 06