WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99077
Permit No.
Basin 106

NOTICE OF INTENT NO. 54265

1. OWNER William Valida
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1399 American Way

2. LOCATION SE ¼ SE ¼ Sec. 8 T. 10 N/S R. 23 E. Douglas Co. County
PERMIT NO. (Issued by Water Resources) Parcel No. 1023-08-002-005 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Sand and Cobbles		0	87	87
Clay + Boulders		87	210	
Decomposed Granite and Clay		210	360'	
D-6 With Hard Layers	✓	360	400	
D-6 Brown Color		400	658	
Gray Fractured Granite	✓	650	670	

Date started 11/21/05, 20
Date completed 12/9/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
156 gpm	3 hrs	

8. WELL CONSTRUCTION
Depth Drilled 670' Feet Depth Cased 670' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	60' Feet
8 3/4 Inches		60 Feet	400' Feet
6 Inches		400' Feet	670' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	18 lbs	.188	+1	400'
5"	13 lbs	.188	380	670'

Perforations:
Type perforation Sawed
Size perforation 1/8 X 3"
From feet to feet
From 380' feet to 400' feet
From 630' feet to 670' feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60' feet to 400' feet

9. WATER LEVEL
Static water level 223' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Treadwell Drilling Inc. Contractor
Address Po Box 599 Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] By driller performing actual drilling on site or contractor
Date Jan 9 06

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627