

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28585

1. OWNER ATLAS CORP ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO BOX 282 20 MILES NORTH  
ELIKA N.V. 89316 ON 3 BAR ROAD  
 2. LOCATION SW 1/4 SE 1/4 Sec 34 T 22 N R 44 E ELIKA County  
 PERMIT NO. MD 259 Parcel No. 27 Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
# NW-1				
SET TRIM				
P.I.P TO T.O.				
PUMP GREAT				
145-20				
CEMENT				
0-20				
PUMP ABANDONED				
GREAT 42				
GALLONS OF WATER				
TO ONE BAG				
MIX 2 BAG				
PUMP ADJUST				
65 GALLONS BLEND				
MIX 2 BAGS				
NEAT CEMENT				

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased 145 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
6 1/4 Inches 0 Feet 145 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.9</u>				

Perforations:  
 Type perforation MILL SLIT  
 Size perforation 0.1010  
 From 125 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 122 feet to 145 feet

9. WATER LEVEL  
 Static water level 125 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 6 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W A C & Well Contractor  
 Address 580 WEST SILVER Contractor  
ELIKA NV 89301  
 Nevada contractor's license number issued by the State Contractor's Board 0012852  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689  
 Signed Darin M...  
 By driller performing actual drilling on site or contractor  
 Date 12-27-05

Date started 12-20-05, 20.....  
 Date completed 12-20-05, 20.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			