



Log No. 99087  
Permit No. \_\_\_\_\_  
Basin 103

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56429

1. OWNER Bill Piccolo ADDRESS AT WELL LOCATION 1671 PINTON HILLS  
MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NE 1/4 Sec 23 T 15 N/S R 20 E Carson County  
PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_  
Subdivision Name 1671 PINTON HILLS 010-096-11

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	6	6
DG		6	48	42
COBBLES		48	60	12
UNKNOWN MATERIAL (LOST CIRCULATION) WHILE DRILLING		60	110	50
FRACTURED GRANITE		110	140	30

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>12 1/4</u> Inches	<u>0</u> Feet <u>140</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 1/2</u>		<u>.188</u>	<u>+1</u>	<u>140</u>

Perforations:  
Type perforation Factory milled  
Size perforation 3/32" x 3"

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 52 ft  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 52 feet to 140 feet

9. WATER LEVEL  
Static water level 70 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature HOT °F Quality CLEAR

Date started 12 DEC 05, 20 \_\_\_\_\_  
Date completed 13 DEC 05, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>1.0</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC.  
Address P.O. Box 255 Carson City, NV 89702  
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167

Signed Jack D. Olson  
By driller performing actual drilling on site or contractor  
Date 21 DEC 05