

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **55363**

1. OWNER John Peckenham ADDRESS AT WELL LOCATION 170 El Molino Spanish Springs
 MAILING ADDRESS 170 El Molino Reno, NV 89506

2. LOCATION NW 1/4 NE 1/4 Sec. 30 T 21N N/S R 21E E Washoe County
 PERMIT NO. _____ Issued by Water Resources 076-380-66 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen
 Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Volcanic black rock		400	415	15
Reddish brown volcanic rock		415	460	45
Brown volcanic rock		460	469	9
Fracture	x	469	470	1
Brown volcanic rock		470	490	20
Fracture	x	490	530	40
Gray volcanic rock		530	577	47
Fracture	x	577	578	1
Gray volcanic rock		578	602	24

Washoe County Well Permit # WL050246

8. WELL CONSTRUCTION
 Depth Drilled 602 Feet Depth Cased 602 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 602 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>10.79</u>	<u>.188</u>	<u>382</u>	<u>602</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 330 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site for contractor
 Date 11/14/2005

Date started 11/8/2005, 19
 Date completed 11/11/2005, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>3</u>	<u>3</u>