WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99117
Permit No.
Basin 104

53717
NOTICE OF INTENT NO. ~~53747~~ ~~53716~~

1. OWNER John Hurzel
MAILING ADDRESS 151 Auther Street
Carson City, NV 89706

ADDRESS AT WELL LOCATION 151 Auther Street
Carson City, Nevada 89706

2. LOCATION NW 1/4 SW 1/4 Sec. 32 T 15N N/S R 20E E Carson City County
PERMIT NO. (Issued by Water Resources) | Parcel No. 009-224-03 | Subdivision Name

3. WORK PERFORMED
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [ ] Deepen
- [x] Abandon
- [ ] Other

4. PROPOSED USE
- [x] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

5. WELL TYPE
- [ ] Cable
- [ ] Rotary
- [ ] RVC
- [ ] Air
- [x] Other Service

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Bail out well from 146 feet to 148 feet,Perforate casing from125 feet up to 42 feet where we found concrete seal,cut off casing 3 feet below finished grade ,install 2 inch trimie pipe to total depth and pump approximatly 11,000 LBS of neat cement. To top of casing to abandon well. T.D. 148 feet				

Date started 12/15/2005, 19__
Date completed 12/16/2005, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 148 Feet Depth Cased 148 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	-3	Feet	148	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	16.9	.188	-3	148

Perforations:
Type perforation Mills Knife
Size perforation 1/4 x 2
From 148 feet to 42 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 42
Placement Method: [x] Pumped [ ] Poured

Seal Type:
- [x] Neat Cement
- [ ] Cement Grout
- [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Larry Welch (By driller performing actual drilling on-site or contractor)
Date 12/22/2005

USE ADDITIONAL SHEETS IF NECESSARY