WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Corrected STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99133
Permit No.
Basin 179

NOTICE OF INTENT NO. 56172

**1. OWNER** BARBRA HAMILTON
**MAILING ADDRESS** BOX 692
McGILL NV 89318

**ADDRESS AT WELL LOCATION** CHERRY CREEK

**2. LOCATION** NW 1/4 SW 1/4 NW 1/4 SW 1/4 Sec. 18 T 23 N/S R 63 E WHITE PINE County
**PERMIT NO.** SW Issued by Water Resources | 008-240-17 Parcel No. | Subdivision Name

**3. WORK PERFORMED**
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| LOAM | | 0 | 9 | 9 |
| SAND + GRAVEL | | 9 | 65 | 56 |
| CLAY | | 65 | 72 | 7 |
| COBBLED SAND | X | 72 | 100 | 28 |
| COBBLED SAND | | 100 | 180 | 80 |
| FRACTURED ROCK | X | 180 | 220 | 40 |

RECEIVED 2006 MAR 13 AM 11:47 STATE ENGINEER'S OFFICE

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| APPROX | 25 | | 5 |

Date started 12-22-05
Date completed 02-10-06

**8. WELL CONSTRUCTION**
Depth Drilled 220 Feet Depth Cased 220 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 100 | Feet |
| 5 1/2 | Inches | 100 | Feet | 220 | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 18.92 | .188 | 72 | 18 |
| 6 | SDR-17 | | 18 | 100 |
| 4 1/2 | SDR-17 | | 94 | 220 |

**Perforations:**
Type perforation SCREEN
Size perforation .050
From 90 feet to 100 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 54
Placement Method: [x] Pumped [x] Poured
Gravel Packed: [x] Yes [ ] No
From 54 feet to 100 feet

Seal Type: [x] Neat Cement [ ] Cement Grout [ ] Concrete Grout
BENTONITE

**9. WATER LEVEL**
Static water level 158 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR dba FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 3-05-06

USE ADDITIONAL SHEETS IF NECESSARY