WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99135
Permit No.
Basin 103

NOTICE OF INTENT NO. 55255

1. OWNER Road & Highway Builders
MAILING ADDRESS P.O. Box 70846 Reno, NV 89507

ADDRESS AT WELL LOCATION Dayton Valley Hydrographic Basin

2. LOCATION SW 1/4 SW 1/4 Sec. 08 T 16 N/S R 22 E Lyon County
PERMIT NO. C238 Issued by Water Resources | 06 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE NDOT Const.
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	2	2
FINE SAND		2	6	4
BROWN CLAY		6	60	54
GRAY CLAY		60	105	45
GRAVEL & SAND	X	105	122	17
BROWN CLAY		122	128	6
SAND & GRAVEL	X	128	134	6
BROWN CLAY		134	167	33
ROCK		167	180	13
BROWN CLAY		180	194	14
COBBLED ROCKS	X	194	207	13
GRAY CLAY		207	228	21
ROCK		228	252	24

Date started 12-5-05, 19__
Date completed 12-14-05, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	300	43	1 HR.

8. WELL CONSTRUCTION
Depth Drilled 252 Feet Depth Cased 252 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	Inches	0 Feet	252 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	+2	252

Perforations:
Type perforation Torch Cut
Size perforation 3/16 X 3
From 100 feet to 252 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 252 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 117 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG dba FERTIG DRILLING (Contractor)
Address P.O. Box 525 (Contractor)
EIKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 12-21-05

USE ADDITIONAL SHEETS IF NECESSARY