


REPORT NO. **A05.102**

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



LOG NO. 99168
PERMIT NO. _____
BASIN φ83

NOTICE OF INTENT NO. **55407**

1. OWNER Don Pressey
MAILING ADDRESS 3404 Skyline View Dr. Reno, NV 89509
2. WELL LOCATION SW 1/4 SW 1/4 SEC. 30 T 18N R 21E E Storey COUNTY
PERMIT NO. _____ PARCEL NO. 03-461-35 SUBDIVISION NAME _____

ADDRESS OF WELL 1250 Yellowjacket Rd.
Virginia City Highlands, NV 89521

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Overburden dirt, yellow rock		0	4	4
Yellow clay & soft rock		4	16	12
Yellow white soft rock - red clay		16	30	14
Reddish brown vol rock		30	45	15
Gray-blue sandy clays		45	70	25
Dk purple hard vol rock		70	85	15
Dk blue-white specked vol rock		85	110	25
Gray-blue vol rock & clays		110	330	220
Blue/green/maroon vol rock		330	368	38
Hard gray-blue clays & rock		368	500	132
Blue-gray w/ specs green vol rock		500	580	80
Maroon VR, blue-gray VR & clays		580	610	30
Blue-gray VR & clay		610	665	55
All maroon VR		665	670	5
Maroon/gray/blue VR & clays		670	710	40
Fractured in & out gray-blue clays and hard VR		710	857	147

8. WELL CONSTRUCTION

Depth Drilled **857** Depth Cased **857**

HOLE DIAMETER (BIT SIZE)

10 Inches **0** Feet **60** Feet
8 1/2 Inches **60** Feet **537** Feet
6 1/8 Inches **537** Feet **857** Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+3	537
5	9.69	.188	517	857

PERFORATIONS:

Type Perforation **Factory** Size Perforation **3/32 x 3**
From **497** Feet to **537** Feet
From **817** Feet to **857** Feet
From _____ Feet to _____ Feet

SURFACE SEAL: Yes No SEAL TYPE:

Seal Depth **60** Neat Cement
 Cement Grout

PLACEMENT METHOD: Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED: Yes No

From **60** Feet to **537** Feet

9. WATER LEVEL

Static Water Level **765** Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature **cool** F Quality **clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**

Address **675 Edison Way**
Reno, NV 89502

DRILLER'S LIC. NO. _____
ON SITE **2189**

Signed *Ryan Thiel*
By driller performing actual drilling on site or contractor

Dated **November 2, 2005**

Notes : Latitude: **N39 degrees 23.355'**
Longitude: **W119 degrees 40.513'**

Date Started **10/18/05** Date Completed **11/2/05**

7. WELL TEST DATA

TEST METHOD Bailor Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		2 hours