WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99206
Permit No.
Basin 104

NOTICE OF INTENT NO. 56729

1. OWNER Pat and Tracy Clark
MAILING ADDRESS 811 E. 5th St.
Carson City, NV 89701

ADDRESS AT WELL LOCATION 811 East 5th. Street,
Carson City, NV.

2. LOCATION SE 1/4 SE 1/4 Sec. 17 T 15N N/S R 20E E Carson County
PERMIT NO. (Issued by Water Resources) Parcel No. 04-021-03 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level in 6" well at 10.9'. Measured depth of well at 31'. Installed 2" pipe and blew debris from bottom of well and blew out debris to 32' where we hit a hard bottom. Installed Mills knife and perforated from 21' back to surface. Installed 30' of 2" tremme pipe and mixed 9 bags of Portland cement with 45 gallons of water and pumped in neat cement from bottom of well to surface. Casing was then cut off 5' below surface.				

Date started 11/22/2005, 19__
Date completed 11/22/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled n/a Feet Depth Cased n/a Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	32'	+1

Perforations:
Type perforation Mills Knife
Size perforation
From 21' feet to surface feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 32'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 10.9' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed (By driller performing actual drilling on-site or contractor)
Date 12/1/2005

USE ADDITIONAL SHEETS IF NECESSARY