WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99210
Permit No.
Basin 065

NOTICE OF INTENT NO. 56242

1. OWNER Newmont mining Corp
MAILING ADDRESS P.O. Box 388 Valmy, NV 89438
ADDRESS AT WELL LOCATION Lone Tree mine 5 miles west of Valmy (Stone House exit)

2. LOCATION NE ¼ NW ¼ Sec. 23 T. 34 N/S R. 42 E. Humbolt County
PERMIT NO. MO 627 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. S23mw2 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drill Replacement well 55' away.				
Abandone old well.				
Clean well out				
Trimmy in Abandonite Slurry from Bottom to top				
92 sks Super plug 5040 gal Slurry				
Slightly over 100% .2 yrd³ 3/8 Hole plug for Bridge 6 sks Cement for 20' Cap 55 gal Slurry 15 Pound				

Date started 11/18, 2005
Date completed 11/18, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 815 Feet Depth Cased 798.5 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
14.75	0	19
10.00	19	815

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75		1/4	0	19
6"		Sch 80	+1.5	798.5

Perforations:
Type perforation Slot
Size perforation .020
From 798.5 feet to 778.5 Blank feet
From 778.5 feet to 578.5 Screen feet
From 578.5 feet to +1.5 Blank feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 76' feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed (By driller performing actual drilling on site or contractor)
Date 11/18/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627