WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99219
Permit No.
Basin 103

NOTICE OF INTENT NO. 56719

1. OWNER Reynen & Bardis Development Co.
MAILING ADDRESS 1380 Greg St., Suite 230
Sparks, NV 89431

ADDRESS AT WELL LOCATION Verre Court in the Riverpark Subdivision near Dayton, NV. (the old Rolling A Ranch headquarters)

2. LOCATION NW 1/4 NW 1/4 Sec. 4 T 16N N/S R 22E E Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. Riverpark (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mobilized to site and removed 140' of 1-1/4" drop pipe with submersible pump. Measured static water level at 15.3' and the depth of the well at 336'. Installed bailer in 8" well and bailed to a depth of 340', where we hit a hard bottom. Installed 8" Mills Knife and perforated casing from 147' back to surface with 4 rows per foot. We removed Mills Knife and installed 336' of 2" tremme pipe. The following day, we pumped in 6 yards of neat cement from the bottom of the well to the surface. Actual well volume should have required 4.4 yards.				

Date started 12/23/2005, 19__
Date completed 12/27/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled n/a Feet Depth Cased 340' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188	0	340'

Perforations:
Type perforation Mills Knife
Size perforation
From 0' feet to 147' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 340'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 15.3' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Frangel (By driller performing actual drilling on-site or contractor)
Date 1/4/2006

USE ADDITIONAL SHEETS IF NECESSARY