COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99230
Permit No.
Basin 105

NOTICE OF INTENT NO. 54342

1. OWNER CORNERSTONE CONSTRUCTION
MAILING ADDRESS P.O. BOX 22270
CARSON CITY, NV 89721

ADDRESS AT WELL LOCATION 2583 NYE DR.
GARDNERVILLE, NV 89423

2. LOCATION NW ¼ NE ¼ Sec 2 T 13N N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1320-02-001-101 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
DG SANDS		3	24	21
COUSE DG SANDS		24	155	131
BROWN CLAY		155	210	55
SMALL COURSE SANDS		210	221	11
BROWN CLAY		221	259	38
COURSE FRACTURED DG SANDS	XX	259	300	41

Date started 11/26, 20 05
Date completed 11/30, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	38'	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 300' Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	300' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8SDR21	4.06	.216	20	300

Perforations:
Type perforation SAW CUT
Size perforation 3X3/32
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☒ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 300 feet

9. WATER LEVEL
Static water level 185' feet below land surface
Artesian flow G.P.M 20+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLIG (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Michael L Hart
By driller performing actual drilling on site or contractor
Date 12/5/05