STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 99234
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 56813

1. OWNER Rawhide Estates, LLC
MAILING ADDRESS 9200 Beechcraft
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
10445 Reins Way
Winnemucca, NV 89445

2. LOCATION NE ¼ NE ¼ Sec 31 T 35N N/S R 38 E
PERMIT/WAIVER No. 10-624-06
*Issued by Water Resources* Parcel No.

Latitude
Longitude
UTM E
N
☐ NAD 27
☐ NAD 83/WGS 84
Subdivision Name:
*County:* Humboldt

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other.....

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other .....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Cobbles & Clay | | 0 | 160 | 160 |
| Consolidated Gravel | | 160 | 190 | 30 |
| Cobbles w/Some Clay | | 190 | 220 | 30 |
| Gravel & Clay | | 220 | 340 | 120 |

Date started 8-Dec , 20 05
Date completed 11-Dec , 20 05

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 3 |

8. *WELL CONSTRUCTION*
Depth Drilled 340 Feet Depth Cased 340 Feet

*HOLE DIAMETER (BIT SIZE)*

| | | From | | To | |
|---|---|---|---|---|---|
| 11 | Inches | 0 | Feet | 340 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

*CASING SCHEDULE*

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +2 | 260 |

*Perforations:*
Type of perforation Mill Slot
Size of perforation 0.09
From 260 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 120
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 120 feet to 340 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. *WATER LEVEL*
*Static water level* 210 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada, Inc., dba Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4975 W. Winnemucca Blvd.
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed C. Jaynes Office
By driller performing actual drilling on site or contractor
Date 1/5/2006

(Rev. 12-05)

USE ADDITIONAL SHEETS IF NECESSARY