



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **29893**

1. OWNER **RICK ANDREWS** ADDRESS AT WELL LOCATION **631 W GARDEN LN**  
 MAILING ADDRESS **631 W GARDEN LN**  
**PAHRUMP, NV**

2. LOCATION **NE** 1/4 **NW** 1/4 Sec. **28** T **20S** N/S R **53E** E **NYE** County  
 PERMIT NO. **39-085-06** Parcel No. **CALVADA VALLEY UNIT 8B** Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	20	20
CALICHE		20	36	16
CLAY		36	74	38
CALICHE	WB	74	86	12
CLAY		86	105	19
CALICHE	WB	105	118	13
CLAY		118	148	30
CALICHE	WB	148	156	8
CLAY		156	175	19
CALICHE	WB	175	200	25

DCNR/DWR RECEIVED  
 MAY 11 2006  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled **200** Feet Depth Cased **200** Feet

HOLE DIAMETER (BIT SIZE)  
 From **10** Inches To **0** Feet  
 From **0** Feet To **200** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:  
 Type perforation **SAWCUT**  
 Size perforation **1/8 X 3**

From	100	feet to	120	feet
From	140	feet to	160	feet
From	180	feet to	200	feet
From		feet to		feet
From		feet to		feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **200** feet

Date started **5/3/2006**, 19  
 Date completed **5/3/2006**, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level **69** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **1220 E MANSE RD** Contractor  
**PAHRUMP, NV. 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**  
 Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **5/8/2006**