WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99314
Permit No.
Basin 162

NOTICE OF INTENT NO. 29619

1. OWNER JOSE CAMBERO
MAILING ADDRESS 5141 S BONNIE ST
PAHRUMP, NV

ADDRESS AT WELL LOCATION 5141 S BONNIE ST

2. LOCATION NE 1/4 NE 1/4 Sec. 11 T 21S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources
44-302-16 Parcel No.
JOYCELYN ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	12	12
CALICHE		12	28	16
CLAY		28	43	15
CALICHE		43	56	13
CLAY		56	78	22
CALICHE	WB	78	96	18
CLAY		96	115	19
CALICHE	WB	115	125	10
CLAY		125	155	30
CALICHE	WB	155	163	8
CLAY		163	185	22
CALICHE	WB	185	200	15

DCNR/DWR
RECEIVED
MAY 18 2006
LAS VEGAS OFFICE

Date started 5/8/2006, 19__
Date completed 5/8/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From	100	feet to	120	feet
From	140	feet to	160	feet
From	180	feet to	200	feet
From		feet to		feet
From		feet to		feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 5/12/2006

USE ADDITIONAL SHEETS IF NECESSARY