

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 99351  
Permit No.  
Basin 085

NOTICE OF INTENT NO 57038  
640 Encanto Fr

1. OWNER **Stephan Massic**  
MAILING ADDRESS **40 Virgil Dr**  
**Reno, NV**

ADDRESS AT WELL LOCATION

2. Location **SE** **NE** 1/4 NE 1/4 Sec 18 T 21N R 21E  
PERMIT NO. PARCEL NO. **076-360-32**

Washoe County

SUBDIVISION NAME

| 3. WORK PERFORMED |   |             | 4. PROPOSED USE                              |            |       | 5. WELL TYPE |        |     |
|-------------------|---|-------------|--|------------|-------|--------------|--------|-----|
| New Well          | Replace                                     | Recondition | <input checked="" type="checkbox"/> Domestic | Irrigation | Test  | Cable        | Rotary | RVC |
| Deepen            | <input checked="" type="checkbox"/> Abandon | Other       | Municipal/Industrial                         | Monitor    | Stock | Air          | Other  | Mud |

6. LITHOLOGIC LOG

| Material                                    | Water Strata | From | To | Thickness |
|---|--------------|------|----|-----------|
| Perfed from 0 to 50'                        |              | 0    |    | 0         |
| Installed neat cement from 375' to surface. |              |      |    | 0         |
| We did get returns                          |              |      |    | 0         |

8. WELL CONSTRUCTION

Depth Drilled **375** feet      Depth Cased **242** feet

HOLE DIAMETER (BIT SIZE)

|        | From | To | feet | feet |
|--------|------|----|------|------|
| inches | 0    |    |      |      |
| inches |      |    |      |      |
| inches |      |    |      |      |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              | 188                 | 1.88                    | 0           | 242       |

Perforations:

Type Perforation Mills Knife

Size perforation 1/4 x 3

| From | feet to | feet |
|------|---------|------|
| 0    | 50      |      |
|      |         |      |
|      |         |      |
|      |         |      |
|      |         |      |

Surface Seal  YES      No      Seal Type:

Depth of Seal **375** feet       Neat Cement

Pumped      Cement Grout

Poured      Concrete Grout

Gravel Packed: Yes      No

From      feet to      feet

2006 JUN -9 AM 10:25  
STATE ENGINEERS OFFICE

Date started 5-8 -06  
Date completed 5-8 -06

7. WELL TEST DATA

| TEST METHOD: | Bailer                        | Pump | Air Lift     |
|--------------|-------------------------------|------|--------------|
| G.P.M.       | Draw Down (Feet Below Static) |      | Time (hours) |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**

NV Contractors No. **14170**  
NV Driller's Lic (on site) **1261**

Signed   
By driller performing actual drilling on site or contractor

Date **5-22-06**